



NOTES:

1. WEEP SCREED SHALL COMPLY WITH ASTM C1063.
2. PROVIDE A MINIMUM OF 26 GALVANIZED SHEET CORROSION-RESISTANT WEEP SCREED WITH A MINIMUM VERTICAL ATTACHMENT FLANGE OF 3-1/2" SHALL BE PROVIDED AT OR BELOW THE FOUNDATION PLATE LINE ON ALL EXTERIOR STUD WALLS.
3. THE WEATHER-RESISTANT BARRIER SHALL LAP THE ATTACHMENT FLANGE, AND THE EXTERIOR LATH SHALL COVER AND TERMINATE ON THE ATTACHMENT FLANGE OF THE SCREED.
4. WHERE NO EXTERNAL CORNER REINFORCEMENT IS USED, LATH SHALL BE FURRED OUT AND CARRIED AROUND CORNERS AT LEAST ONE SUPPORT ON FRAME CONSTRUCTION.

UNIVERSITY OF CALIFORNIA SANTA CRUZ Physical Planning and Construction	SHEET TITLE	DRAWN	LOCATION	FILE NO.
	WEEP SCREED & SHT. METAL FLASHING	JO		REF
	BUILDING OR PROJECT	CHECKED	SCALE	SHEET
	CAMPUS STANDARDS	AB	N.T.S.	07.6-21
		APPROVED	DATE	OF
		PP&C	01/22/04	